

## FIRE SAFETY CERTIFICATE

No. 621.

Dated: 29/12/2021.....

Certified that the **St. Paul's Academy, Saheb Kothi, Dariyapur, Bhagalpur, Bihar** comprised of Ground Floor, First Floor, Second Floor, Third Floor and Fourth Floor owned by **St. Paul Anglo Indian Education Society** have complied with the fire prevention and fire safety requirements in accordance with rule of State Fire Service Rules, and verified by the officers concerned of Fire Service on 29 December, 2021 in the presence of **Mrs. Kathleen Aleen Quadros, Principal, St. Paul's Academy, Saheb Kothi, Dariyapur, Bhagalpur, Bihar** and **Mr. Rana Raj Singh, Manager, St. Paul's Academy, Saheb Kothi, Dariyapur, Bhagalpur, Bihar** and that the building/premises is fit for occupancy of classes from Std I to Std VIII and above with effect from 29/12/2021 for a period of one year in accordance with rule and subject to compliance of the conditions.

Issued on 29/12/2021 at Bhagalpur by Fire Safety Officer, Bhagalpur.

Signature with Seal:   
Name :

Designation : Fire Station Officer, Bhagalpur  
अधिष्ठान अग्निशमन अधिकारी  
भागलपुर


To,  
**The Secretary/Principal,**  
St. Paul's Academy,  
Saheb Kothi, Dariyapur,  
Bhagalpur, Bihar


### ENDORSEMENT

The No Objection Certificate issued by Fire Service stand cancelled and annulled due to

.....  
..... (Reasons to be recorded).

(Name and designation of the authorized signatory)

  
**Principal**  
ST. PAUL'S ACADEMY  
Dariyapur, Sajour Road  
Nathnagar, Bhagalpur  
BIHAR-812006

  
**Manager**  
ST. PAUL'S ACADEMY  
Dariyapur, Sajour F  
Nathnagar, Bhagalpur  
BIHAR-812006

झापांक 621 /  
कार्यालय अग्निशमालय पदाधिकारी, भागलपुर.  
दिनांक 30/12/2021

प्रेषक,

अधिष्ठान अग्निशम पदाधिकारी,  
भागलपुर।

सेवा में,

सर्वश्री, सैर जॉल एकेडमी, (6+1)  
सोले कौली, हरियापुर, भागलपुर

विषय:- अग्निशामक यंत्रों/उपकरणों का जाँच प्रतिवेदन  
महाशय,

उपयुक्त विषय में प्रमाणित करना है कि आपके प्रतिष्ठान/भवन में रखे जाने वाले निम्नांकित आग से बचाव एवं सुरक्षा के निम्नलिखित अग्निशमन उपकरणों की दिनांक 30/12/2021 को जाँच की गयी, जो सही एवं क्रियाशील पाया।

- (1) CO2 type Fire extinguisher 4.5 kg — 02 Nos
- (2) CO2 type Fire extinguisher 02 kg — 02 Nos
- (3) ABC type Fire extinguisher 6 kg — 05 Nos
- (4) ABC type Fire extinguisher 9 kg — 03 Nos
- (5) Fire Bucket — 04 Nos
- (6) Smearable Box —


01. प्रमाणित किया जाता है कि आपके द्वारा प्रस्तुत सभी अग्निशमन यंत्र / उपकरण दिनांक 30/12/2021 व अन्तर्गत वर्ष 2022 के लिए ठीक है।
02. प्रमाण पत्र इस शर्त के साथ है कि अपने पुरे अवधि में सभी अग्निशामक यंत्रों / उपकरणों को मली भांति से संधारण भारतीय मानक ब्यूरो 15683/2006 के अनुसार करेंगे। यदि सभी अग्निशमन यंत्रों/ उपकरणों का मली भांति से संधारण नहीं करते है तो इसके लिए स्वयं जवाबदेह समझे जाएँगे। और बीच में भी इसका नवीकरण रद्द कर दी जायेगी।
03. एक वर्ष पूर्ण होने से एक दिन पूर्व ही इनकी पुनः रिफिलिंग किसी मान्यता प्राप्त फर्म से कराकर इनकी सक्रियता की जाँच इस कार्यालय से करा लेंगे।
04. वर्ष में कम से कम दो बार मॉक ड्रिल कराना सुनिश्चित करेंगे।

  
Principal

ST. PAUL'S ACADEMY  
Dariyapur, Sajour Road  
Nathnagar, Bhagalpur  
BIHAR-812006



Manager  
ST. PAUL'S ACADEMY  
Dariyapur, Sajour Road  
Nathnagar, Bhagalpur  
BIHAR-812006

  
29/12/2021  
अग्निशमन पदाधिकारी  
अधिष्ठान  
भागलपुर