

**REGARDING SAFE DRINKING WATER AND SANITARY
CONDITION**

Certificate

No. 66

DATE 02/05/2026

*It is certified that an inspection team headed by— Mr. Jai Kishan Kumar
(Assistant Chemist) from P. H. Division Bhagalpur East, Bhagalpur
inspected the S.T. Paul's Academy Sahel Kothi, Dariyapur, Bhagalpur
on 28.04.2026 and found the S.T. Paul's Academy Sahel Kothi,
Dariyapur, Bhagalpur has safe drinking water facilities for the students and
members of staff institution and is maintaining the hygienic sanitation condition in the school
campus as per the norms prescribed by the Central/State/U.T Govt.*

The above valid for a period of- **One Year (02.05.2026 to 01.05.2027).**

Signature With Seal:-

Kumar
02/05/26

Name

:- Sanjay K. Paswan

Designation

:- Assistant Research Officer

To,

*S.T. Paul's Academy
Sahel Kothi, Dariyapur
Bhagalpur
Bihar-812006*



Government Of Bihar

Regional Water Testing Laboratory

Public Health Engineering Department,
Bhagalpur

Ref.No. EE-1402 Dt-22/04/2026

Date of Sampling - 28.04.2026

Name of School :- ST.Paul's Academy

Sample Collected By- Lab Staff
Source of Sample- Raw water

PHYSICO-CHEMICAL & BACTERIOLOGICAL TEST REPORT

S.No.	Location			Physico - Chemical and Bacteriological Parameters													Remarks			
	Block	Panchayet	Village	Habitation	Name	pH	Turb.	EC	TDS	TH	Ca	Mg	Cl	Alka.	Fe	NO ₃		SO ₄	F	As
1					ST.Paul'S Academy,Saheb Kothi,Dariyapur,Bhagalpur(Bihar) - 812006	7.48	0.76	533.0	267.0	136.1	54.4	18.56	40.5	125.9	0.22	3.85	6.9	0.17	NA	Negative
					Desirable Limit*	6.5-8.5	1.0	-	500	300	75	30	250	200	1.0	45.0	200	1.0	0.01	-
					Permissible Limit* in absence of alternate source	NR	5.0	-	2000	600	200	100	1000	600	NR	NR	400	1.5	NR	**

NA=Not Applicable

Memo No.... RL-66

Date ... 02/05/2026

Copy Forwarded To : 1. Executive Engineer, P.H.Division Bhagalpur East, for kind information and necessary action.

Sumax
02/05/26
Lab Incharge(A.R.O)